



# El Toro Water District

## WATER NOTES

1. EL TORO WATER DISTRICT SHALL BE NOTIFIED 48 HOURS (2 working days) PRIOR TO CONSTRUCTION: PHONE: (949) 837-0660
2. WATER SYSTEM MATERIALS AND CONSTRUCTION SHALL CONFORM TO THE STANDARDS AND SPECIFICATIONS OF EL TORO WATER DISTRICT.
3. ALL OTHER UTILITIES SHALL BE NOTIFIED 48 HOURS PRIOR TO EXCAVATION THROUGH UNDERGROUND SERVICE ALERT: 1-800-422-4133.

IN AREAS OF POSSIBLE CONFLICT OF WATER LINE AND OTHER UTILITIES, CONTRACTOR SHALL CAREFULLY HAND EXCAVATE, EXPOSE AND LOCATE THOSE FACILITIES.

4. FIRE HYDRANTS SHALL BE PER EL TORO WATER DISTRICT STANDARDS AND SPECIFICATIONS 'G'. THE 4" FIRE HYDRANT OPENING SHALL FACE THE STREET.
5. FIRE HYDRANTS THAT ARE NOT IN SIDEWALK AREAS SHALL HAVE A MINIMUM OF 3' X 3' X 4" THICK PAD POURED AROUND IT.
6. PUBLIC FIRE HYDRANTS SHALL BE PAINTED "SCHOOLBUS YELLOW" OR APPROVED EQUAL BEFORE RELEASE FOR OCCUPANCY.
7. WATER METERS SHALL BE STAKED BY DEVELOPER'S ENGINEER AND SHOWN ON WATER PLAN WITH DIMENSIONS TO NEAREST LOT PROPERTY LINE ALONG RIGHT OF WAY.
8. WATER METER BOXES SHALL BE A MINIMUM OF FIVE (5) FEET FROM ANY DRIVEWAY AND SHALL NOT BE INSTALLED IN SIDEWALKS OR OTHER CONCRETE AREAS WITHOUT PRIOR WRITTEN APPROVAL OF THE EL TORO WATER DISTRICT.
9. ALL WATER SERVICE LINES SHALL BE CHISEL MARKED WITH A 'W' ON THE FACE OF THE CURB WHERE IT PASSES UNDER CURB.
10. ALL VALVES SHALL BE CHISEL MARKED IN THE NEAREST CURB FACE WITH A 'V' AND FOOTAGE FROM CURB FACE TO VALVE. WHERE VALVE IS IN AN INTERSECTION, TWO CHISEL MARKS FROM DIFFERENT CURB FACES AT THE NEAREST B.C. SHALL BE GIVEN. WHERE VALVE IS IN MID-BLOCK, ONE CHISEL MARK AT A RIGHT ANGLE TO THE VALVE SHALL BE GIVEN.
11. ALL WATER FACILITIES SHALL BE HYDROSTATIC TESTED BY AN APPROVED INDEPENDENT TESTING COMPANY AND RESULTS SHALL BE SUBMITTED, IN WRITING, TO THE DISTRICT'S OFFICE.

